

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7320-1209:200 Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** System Sensor, 3825 Ohio Avenue, St. Charles IL 60174  
Contact: \*Trish Linhart (630) 377-6674 Fax (630) 377-7245

**DESIGN:** Models SP2C2415, SP2C241575, SP2C2430, SP2C2460, SP2C2475, SP2C2495, SP2C24115 and SP2C24177 speaker/strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 25 Vrms or 70 Vrms  
15cd, 15/75cd, 30cd, 60cd, 75cd, 95cd, 115cd, 177cd

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as speaker/strobes suitable for the hearing impaired application when used with separately listed compatible fire alarm control units. Suitable for wall or ceiling mount. For indoor use only.

These speaker/strobes do not generate a distinctive three-pulse temporal code pattern (for total evacuation) as required per NFPA 72, 1999 edition. If required, the appliances must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

\*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**